

【施設維持管理情報 令和4年】

9月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木		175	175		1,000	1,000		1.5	0.8
2 金	175	175	175	1,000	1,000	1,000	1.2	1.2	0.9
3 土		175	175		1,000	1,000		0.9	1.0
4 日		177	170		1,000	1,000		1.1	1.3
5 月		175	175		1,000	1,000		1.7	1.2
6 火		173	172	1,000	1,000	1,000	2.1	1.5	0.8
7 水		172	175		1,000	1,000		1.2	1.0
8 木		175	175		1,000	1,000		1.1	1.0
9 金		175	175	1,000	1,000	1,000	1.5	1.9	1.2
10 土		177	175		1,000	1,000		1.0	0.8
11 日									
12 月	175	175		1,000	1,000		0.9	1.5	
13 火	175	176	175	1,000	1,000	1,000	1.3	1.0	1.5
14 水	175	175	175	1,000	1,000	1,000	1.7	1.2	0.9
15 木	175	175	175	1,000	1,000	1,000	1.7	1.8	0.7
16 金		175	175		1,000	1,000		2.1	1.0
17 土									
18 日									
19 祝									
20 火		175	175		1,000	1,000		1.5	1.5
21 水									
22 木									
23 祝									
24 土	175	175	175	1,000	1,000	1,000	1.0	1.7	2.0
25 日									
26 月									
27 火									
28 水									
29 木	175	175	175	1,000	1,000	1,000	1.5	1.2	1.3
30 金									