

【施設維持管理情報 令和7年】

2月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00
1 土		172	171		1,000	999		1.0	0.0
2 日									
3 月	168	170	171	1,000	1,000	1,001	0.0	0.0	0.0
4 火		170	171		999	1,000		0.0	0.0
5 水	172	171	170	1,000	1,000	1,000	8.0	1.0	0.0
6 木		174	171		1,000	1,000		0.0	0.0
7 金	173	171	171	1,000	1,000	1,000	2.0	1.0	0.0
8 土		171	170		1,002	999		0.0	0.0
9 日									
10 月	171	172	171	999	1,000	1,000	1.0	0.0	0.0
11 祝		173	172		1,000	1,000		0.0	0.0
12 水	172	174	172	1,000	1,000	1,000	0.0	0.0	0.0
13 木		172	171		1,001	999		0.0	0.0
14 金	172	171	171	1,000	1,000	1,000	7.0	1.0	0.0
15 土		170	171		1,000	1,000		0.0	0.0
16 日									
17 月	171	170	171	1,000	1,000	1,000	0.0	0.0	0.0
18 火	170	171	170		1,000	1,000		7.0	0.0
19 水	171	171	170	1,000	1,000	999	0.0	0.0	0.0
20 木	169	170	172	1,000	1,000	1,000	1.0	0.0	0.0
21 金	171	170	171	999	1,001	1,000	0.0	0.0	0.0
22 土	172	171	170	1,000	1,000	970	3.0	0.0	10.0
23 日									
24 祝	171	170	172	1,000	1,000	1,000	0.0	0.0	0.0
25 火		171	172		998	1,000		2.0	0.0
26 水	171	170	170	1,000	1,000	1,000	0.0	0.0	0.0
27 木	171	172	170	1,000	1,000	1,000	0.0	0.0	0.0
28 金	168	171	170	1,000	1,000	1,000	3.0	0.0	0.0