

【施設維持管理情報 令和7年】

3月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00
1 土		171	170		1,000	1,000		1.0	0.0
2 日									
3 月	172	171	170	1,000	1,000	999	0.0	0.0	0.0
4 火		169	170		1,000	1,000		1.0	0.0
5 水	170	171	171	999	1,001	1,000	0.0	0.0	0.0
6 木		172	170		1,000	1,000		10.0	0.0
7 金	171	170	170	1,000	1,000	1,001	0.0	0.0	0.0
8 土	170	171	170	990	1,000	999	0.0	0.0	10.0
9 日									
10 月	168	171	172	1,000	1,000	1,000	0.0	0.0	0.0
11 火		172	170		1,000	999		0.0	0.0
12 水	170	171	170	1,000	1,000	1,000	0.0	0.0	0.0
13 木	171	170	170	1,000	1,000	1,001	0.0	0.0	0.0
14 金	171	170	171	999	1,001	1,002	3.0	0.0	0.0
15 土	172	168	170	999	1,000	1,000	1.0	0.0	13.0
16 日									
17 月	170	171	170	1,000	1,000	1,000	0.0	0.0	0.0
18 火		170	171		1,000	998		0.0	0.0
19 水	171	171	171	1,000	1,000	999	0.0	0.0	0.0
20 祝		170	172		1,000	1,001		1.0	0.0
21 金	168	172	169	998	999	1,000	0.0	0.0	0.0
22 土		171	170		1,000	1,000		0.0	0.0
23 日									
24 月	169	172	172	1,000	1,000	1,000	0.0	0.0	0.0
25 火		171	170		998	999		0.0	0.0
26 水	171	170	170	1,000	1,000	1,001	0.0	0.0	0.0
27 木		171	171		1,000	1,000		1.0	0.0
28 金	170	170	172	1,000	1,000	1,000	0.0	0.0	0.0
29 土	171	171	170	999	999	1,000	0.0	0.0	8.0
30 日									
31 月	170	171	170	1,000	1,000	1,000	0.0	0.0	0.0

有限会社 栄晃