

【施設維持管理情報 令和7年】

4月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00
1 火		171	170		1,000	1,000		1.0	0.0
2 水	164	176	170	1,000	999	1,000	0.0	0.0	0.0
3 木		172	171		1,000	1,001		1.0	0.0
4 金	170	171	170	1,000	1,000	1,000	0.0	0.0	0.0
5 土	170	170	169	999	1,000	995	8.0	0.0	0.0
6 日									
7 月	171	170	171	1,000	1,000	1,000	0.0	0.0	0.0
8 火		172	171		999	1,000		10.0	0.0
9 水	172	171	170	1,000	1,000	1,000	0.0	0.0	0.0
10 木	171	170	171	999	1,000	1,000	1.0	0.0	0.0
11 金	171	171	170	1,000	1,000	1,000	0.0	0.0	0.0
12 土		170	171		998	1,000		0.0	0.0
13 日									
14 月	171	170	172	1,000	1,000	999	0.0	0.0	0.0
15 火		169	169		1,000	1,000		0.0	0.0
16 水	171	170	171	1,000	1,000	1,000	3.0	0.0	0.0
17 木		170	170		1,000	998		0.0	0.0
18 金	172	173	171	999	1,002	1,000	0.0	0.0	0.0
19 土	172	171	170	1,000	1,000	990	1.0	0.0	0.0
20 日									
21 月	170	168	171	1,000	1,000	1,000	0.0	1.0	0.0
22 火		171	170		999	1,001		0.0	0.0
23 水	171	170	171	1,000	1,000	1,000	0.0	0.0	0.0
24 木	171	170	171	999	1,000	1,000	10.0	0.0	0.0
25 金	170	170	171	1,000	1,000	1,000	0.0	0.0	0.0
26 土	172	168	170	999	1,000	990	3.0	0.0	10.0
27 日									
28 月	171	170	172	1,000	1,000	1,000	0.0	0.0	0.0
29 祝	170	171	170	999	1,000	999	0.0	0.0	0.0
30 水	171	170	171	1,000	1,000	1,000	3.0	0.0	0.0