

【施設維持管理情報 令和7年】

8月

項目 時間 日	集塵器に流入する燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度(二次焼却炉内、°C)			排ガス中の一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	172	171	171	1,000	1,000	1,000	1.0	0.0	0.0
2 土	170	169	172	1,000	1,001	990	0.0	0.0	0.0
3 日									
4 月	172	171	172	1,001	999	1,000	0.0	0.0	0.0
5 火		172	172		1,000	1,000		3.0	0.0
6 水	172	171	171	1,000	1,000	999	1.0	0.0	0.0
7 木		170	171		1,000	1,000		1.0	0.0
8 金	169	171	172	1,000	999	1,001	0.0	0.0	0.0
9 土		172	173		1,000	1,000		2.0	0.0
10 日									
11 祝	171	170	171	1,000	1,000	999	0.0	0.0	0.0
12 火		171	172		1,000	1,000		0.0	0.0
13 水	170	171	171	999	1,000	1,001	7.0	0.0	0.0
14 木									
15 金									
16 土									
17 日									
18 月	172	173	171	1,000	1,000	1,001	0.0	0.0	0.0
19 火		171	170		999	999		1.0	0.0
20 水	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
21 木		173	172		1,001	1,000		1.0	0.0
22 金	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
23 土	172	171	170	999	1,001	1,000	0.0	0.0	0.0
24 日	171	172	170	1,000	999	1,000	0.0	0.0	0.0
25 月	172	172	171	1,000	1,000	999	1.0	1.0	0.0
26 火		174	171		999	1,000		0.0	0.0
27 水	171	169	172	1,000	1,000	1,000	1.0	0.0	0.0
28 木		171	170		1,001	1,000		0.0	0.0
29 金	171	170	171	1,000	1,000	1,000	10.0	0.0	0.0
30 土	171	172	171	999	999	999	2.0	0.0	0.0
31 日									