

【施設維持管理情報 令和7年】

10月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	171	172	172	1,000	1,001	1,000	1.0	0.0	0.0
2 木		169	171		999	1,000		1.0	0.0
3 金	170	171	173	1,000	1,000	1,000	0.0	0.0	0.0
4 土	172	174	172	990	1,000	1,000	0.0	0.0	1.0
5 日	170	172	172	1,000	1,000	1,000	0.0	0.0	0.0
6 月	171	171	173	1,000	1,001	999	4.0	0.0	0.0
7 火		172	172		1,000	1,000		0.0	0.0
8 水	171	172	173	1,000	1,000	1,000	0.0	0.0	0.0
9 木	169	170	172	999	1,000	1,001	7.0	0.0	0.0
10 金	172	171	171	1,000	1,000	1,000	1.0	0.0	0.0
11 土	171	172	172	1,000	1,000	990	0.0	0.0	0.0
12 日									
13 祝	171	172	172	1,000	1,000	1,000	11.0	0.0	0.0
14 火		171	172		1,000	1,001		0.0	0.0
15 水	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
16 木	172	171	173	998	999	1,000	1.0	1.0	0.0
17 金	172	173	172	1,000	1,000	1,000	0.0	0.0	0.0
18 土	171	172	171	999	1,000	1,000	0.0	0.0	0.0
19 日									
20 月	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
21 火	172	171	171	1,000	1,000	1,000	0.0	0.0	0.0
22 水	171	172	173	1,000	1,000	999	0.0	0.0	0.0
23 木		170	172		1,000	1,000		10.0	0.0
24 金	172	172	173	1,000	1,000	999	0.0	0.0	0.0
25 土	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
26 日									
27 月	172	169	172	1,000	1,000	999	0.0	0.0	0.0
28 火		171	170		999	1,001		1.0	0.0
29 水	172	173	172	1,000	1,000	1,000	0.0	0.0	0.0
30 木	171	172	172	999	999	1,000	6.0	0.0	0.0
31 金	170	171	171	1,000	1,000	1,000	0.0	0.0	0.0

有限会社 栄晃