

【施設維持管理情報 令和7年】

12月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月									
2 火		168	170		1,000	1,000		2.0	0.0
3 水	170	171	172	999	1,000	1,000	1.0	0.0	0.0
4 木	171	172	172	1,000	1,001	1,000	0.0	0.0	0.0
5 金	170	171	172	1,000	1,000	1,000	0.0	1.0	0.0
6 土	173	172	171	1,000	1,000	1,000	0.0	0.0	0.0
7 日									
8 月	171	172	172	998	999	1,000	2.0	0.0	0.0
9 火	172	173	172	1,000	1,000	1,001	0.0	0.0	0.0
10 水	171	172	170	1,000	1,000	1,000	0.0	0.0	0.0
11 木	170	172	171	999	1,000	1,001	1.0	0.0	0.0
12 金	174	172	172	1,000	1,000	1,000	0.0	0.0	0.0
13 土	172	171	170	999	999	1,001	13.0	0.0	0.0
14 日									
15 月	169	172	171	1,000	1,000	1,000	10.0	0.0	0.0
16 火	172	173	172	1,000	1,000	1,001	7.0	0.0	0.0
17 水	171	172	172	1,000	1,000	999	0.0	0.0	0.0
18 木	172	173	171	1,000	1,000	1,000	0.0	0.0	0.0
19 金	172	172	173	1,000	1,000	1,000	5.0	1.0	0.0
20 土	170	169	171	998	999	999	3.0	0.0	0.0
21 日									
22 月	172	172	172	1,000	1,000	1,000	0.0	0.0	0.0
23 火	171	170	172	1,000	1,000	1,000	11.0	0.0	0.0
24 水	171	171	173	1,000	1,000	999	8.0	0.0	0.0
25 木	172	172	172	1,000	1,000	1,000	0.0	0.0	0.0
26 金	170	169	172	999	1,000	999	0.0	0.0	0.0
27 土	172	173	172	1,000	1,000	1,000	1.0	1.0	0.0
28 日	172	172	172	1,000	1,000	1,000	0.0	0.0	0.0
29 月	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
30 火									
31 水									