

【施設維持管理情報 令和8年】

5月

項目 時間 日	集塵器に流入する燃焼ガスの温度(℃)			燃焼中の燃焼ガス温度 (二次焼却炉内、℃)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00	10:00 ～13:00	13:00 ～16:00	16:00 ～19:00
1 金									
2 土									
3 日									
4 祝									
5 祝									
6 祝									
7 木									
8 金									
9 土									
10 日		172	173		800	800		25.0	20.0
11 月	173	172	173	800	900	900	11.0	0.0	0.0
12 火	172	171	173	1,000	1,000	1,000	0.0	0.0	0.0
13 水	173	172	173	999	1,000	1,000	1.0	0.0	0.0
14 木	171	173	174	1,000	1,000	999	0.0	0.0	0.0
15 金	172	173	173	1,000	1,000	1,000	0.0	0.0	0.0
16 土	170	172	173	1,000	1,000	950	0.0	0.0	0.0
17 日									
18 月	172	173	174	1,000	1,000	1,000	3.0	0.0	0.0
19 火		170	171		999	1,000		0.0	0.0
20 水	169	171	172	1,000	1,000	1,000	0.0	0.0	0.0
21 木	172	173	173	1,000	998	1,000	0.0	0.0	0.0
22 金	172	173	172	1,000	1,000	1,000	0.0	0.0	0.0
23 土	171	172	173	990	1,000	1,000	11.0	0.0	0.0
24 日									
25 月	169	172	172	999	1,000	1,000	1.0	0.0	0.0
26 火		172	173			1,000		0.0	0.0
27 水	171	172	172	1,000	1,000	1,000	0.0	0.0	0.0
28 木	172	172	171	999	999	999	0.0	0.0	0.0
29 金	171	169	172	1,000	1,000	1,000	0.0	0.0	0.0
30 土	172	172	173	999	1,000	1,000	0.0	0.0	0.0
31 日									